

# APPENDIX 7D

---

## Data Formats

**List of Tables**

Table 7D-1 Data Requirements for Building the Network of a Hydraulic Model ..... 1

Table 7D-2 Data Requirements for Storage Facilities and Pumps ..... 2

Table 7D-3 Data Requirements for Weirs, Orifices, Valves, Sluice Gates, and Flap Gates ..... 4

Table 7D-4 Data Requirements for Hydrobrakes or Leaping Weirs ..... 5

# I. INTRODUCTION

The following tables list data types and naming convention of each component of a computer model of a study area:

1. Data requirements for building the network of a hydraulic model (Table 1)
2. Data requirements for storage facilities and pumps (Table 2)
3. Data requirements for weirs, orifices, valves, sluice gates, and flap gates (Table 3)

Reference field names corresponding to each type of information in GIS can be found in DSG section 7.5.2, Hydraulic Conveyance System Model Data.

**Table 7D-1**  
**Data Requirements for Building the Network of a Hydraulic Model**

Description	Units, Field ID, or Data Type	Sample Data	Data Source
Pipes and Forcemains			
Upstream Node ID	S_ENDPT_ID or D_ENDPT_ID	046E-090	GIS
Downstream Node ID	S_IMSID or D_ENDPT_ID	059-072	GIS
System Type		Combined	GIS
Asset ID	[U/S node ID]_[D/S node ID]	046E-090_059-072	GIS
(Pipe) Length	Ft	325.0	GIS
(Pipe) Shape		CIRC	GIS
(Pipe) Width	In	8.0	GIS
(Pipe) Height	In	8.0	GIS
(Pipe) Material		Conc	GIS or as-builts
(Pipe) Roughness (Manning's n, Chezy's C, Hazen-Williams' C, or Darcy-Weisbach's f)		0.013	Tabulated values based upon pipe material, and/or field observation
Upstream Invert Level	ft AD <sub>1</sub>	87.800	GIS <sub>3</sub>
Downstream Invert Level	ft AD <sub>1</sub>	86.600	GIS <sub>3</sub>
Type of pipes	Gravity or Forcemain	Gravity	GIS
Flap Gate (one-way valve)		Yes	GIS, As-builts
Owner		SPU	GIS
Status	Active or abandoned	Active	GIS

Chapter 7 Drainage and Wastewater System Modeling  
Appendix 7D Data Formats

Description	Units, Field ID, or Data Type	Sample Data	Data Source
Nodes			
Node ID	S_ENDPT_ID or D_ENDPT_ID	046E-090	GIS
Node Type		Manhole	GIS
System Type		Combined	GIS
X-coordinate	ft NAD832	1282611.9	GIS
Y-coordinate	ft NAD832	213245.8	GIS
Ground Level	ft ADI	96.000	GIS
Invert Elevation	ft ADI	87.8	GIS, or As-builts
Diameter of network element (e.g. manhole)	ft	4	GIS, As-builts, Field Observation, or SPU Standard Plans
Cover Type	SEALED (Pressurized) or UNSEALED	UNSEALED	Field observation, or As-builts
Owner		SPU	GIS
Status	Active or abandoned	Active	GIS

Notes

<sup>1</sup> ft AD = feet above NAVD88-North American Vertical Datum of 1988 datum

<sup>2</sup> ft NAD83 = NAD\_1983\_HARN\_StatePlane\_Washington\_North\_FIPS\_4601\_Feet

<sup>3</sup> Use the minimum of ELEV1, ELEV2, ELEV3, ELEV4 or CINVERT – DEPTH unless information shown on As-builts drawings indicates otherwise. Please note that the node invert can also be calculated from the lowest pipe invert connected to the node.

**Table 7D-2  
Data Requirements for Storage Facilities and Pumps**

Description	Units, Field ID, or Data Type	Sample Data	Data Source
Wet Wells or Other Storage Facilities			
Node ID	S_ENDPT_ID or D_ENDPT_ID	059-453	GIS
Node/Link Type		Storage	GIS
System Type		Combined	GIS
Asset ID	ST[S_ENDPT_ID], or other City's distinct identifier	ST059-453	GIS
X-coordinate  (if storage facilities are modeled as nodes)	ft NAD832	1282611.9	GIS
Y-coordinate  (if storage facilities are modeled as nodes)	ft NAD832	213245.8	GIS

Description	Units, Field ID, or Data Type	Sample Data	Data Source
Invert Elevation	ft ADI	16.3	GIS, As-builts, or Field measurement
Ground Level	ft ADI	96.000	GIS
Depth- Surface Area relationship of facilities	ft ADI - Sq.ft	Tabulated data of depth and corresponding surface area	Field measurement or As-builts
Owner		SPU	GIS
Status	Active or abandoned	Active	GIS
<b>PUMPS</b>			
Upstream Node ID	S_ENDPT_ID or D_ENDPT_ID	059-453	GIS
Downstream Node ID	F[S_ENDPT_ID] or F[D_ENDPT_ID]	F059-453	Dummy node connecting the end of the pump element and the beginning of the forcemain link
Type (Pump type)		FIXPMP	Field observation, or as-builts
System Type		Combined	GIS
Asset ID	PS_[U/S node ID]_#	PS_059-453_1	
Switch On Level	ft AD <sup>1</sup>	16.57	Field measurement
Switch Off Level	ft AD <sup>1</sup>	11.7	Field measurement
Pump Discharge Information	gpm, or gpm-ft	Fixed discharge value, or tabulated Head Discharge data	Field measurement
Operation Sequence and Logics	Set point driven or RTC	Real Time Control (RTC) Input	Field Information
Owner		SPU	GIS
Status	Active or abandoned	Active	GIS

**Notes**

<sup>1</sup> ft AD = feet above NAVD88-North American Vertical Datum of 1988 datum

<sup>2</sup> ft NAD83 = NAD\_1983\_HARN\_StatePlane\_Washington\_North\_FIPS\_4601\_Feet

**Table 7D-3**  
**Data Requirements for Weirs, Orifices, Valves, Sluice Gates, and Flap Gates**

Description	Units, Field ID, or Data Type	Sample Data	Data Source
Upstream Node Name	S_ENDPT_ID or D_ENDPT_ID	059-456	GIS
Downstream Node Name	For a <i>Weir</i> : W[S_ENDPT_ID] or W[D_ENDPT_ID]  For an <i>Orifice</i> : R[S_ENDPT_ID] or R[D_ENDPT_ID]  For a <i>Valve</i> not modeled as an imbedded feature in a pipe:  V[S_ENDPT_ID] or V[D_ENDPT_ID]  For a <i>Sluice or Flap Gate</i> : G[S_ENDPT_ID] or G[D_ENDPT_ID]	W059-456	
Link/node Type	The type of Weir, Orifice, Valve, Sluice gate, or flap gate	BRWeir (broad crested weir)	Field measurement
System Type	Combined, Storm, or Sanitary	Combined	GIS
Asset ID	For a <i>Weir</i> : WR_[S_ENDPT_ID] or WR_[D_ENDPT_ID]  For an <i>Orifice</i> : OR_[S_ENDPT_ID] or OR_[D_ENDPT_ID]  For a <i>Valve</i> not modeled as an imbedded feature in a pipe link: VV_[S_ENDPT_ID] or VV_[D_ENDPT_ID]  For a <i>Sluice Gate</i> : SG_[S_ENDPT_ID] or SG_[D_ENDPT_ID]  For a <i>Flap Gate</i> : FG_[S_ENDPT_ID] or FG_[D_ENDPT_ID]	WR_059-456	
Crest Elevation	ft AD <sub>1</sub>	18.8	Field measurement
Geometry (under both <i>free flow</i> and <i>submerged</i> condition)	Structure dependent	Essential geometric properties of the structures (under both free flow and submerged condition)	Field measurement, or As-builts
Primary (free flow) and Secondary (submerged) discharge coefficients <sub>2</sub>		0.6	As-builts, Manufacturers' values, or typical values
Flap Gate (one-way valve)	Yes/No (checked / unchecked)	Yes (checked)	GIS, As-builts
Operation Sequence and Logics	Static or RTC	Real Time Control (RTC) Input	Field Information

Description	Units, Field ID, or Data Type	Sample Data	Data Source
Owner		SPU	GIS
Status	Active or abandoned	Active	GIS

**Notes**

<sup>1</sup> ft AD = feet above NAVD88-North American Vertical Datum of 1988 datum

<sup>2</sup> It should be noted that the default weir coefficients in modeling platform may be too high or too low. Please verify, document, and use appropriate values and do not default to default values in model

**Table 7D-4  
Data Requirements for Hydrobrakes or Leaping Weirs**

Description	Units, Field ID, or Data Type	Sample Data	Data Source
Upstream Node ID	S_ENDPT_ID or D_ENDPT_ID	059-453	GIS
Downstream Node ID	For a Hydrobrake: HB[S_ENDPT_ID] or HB[D_ENDPT_ID]  For a Leaping Weir: L[[S_ENDPT_ID]] or L[D_ENDPT_ID]	HB059-453	Dummy node connecting the end of the structure to the beginning of the downstream link
System Type		Combined	GIS
Asset ID	For a Hydrobrake: HB_[S_ENDPT_ID] or HB_[D_ENDPT_ID]  For a Leaping Weir: LW[[S_ENDPT_ID]] or LW[D_ENDPT_ID]	HB_059-453	
Upstream Invert Level	ft AD I	87.800	GIS2
Downstream Invert Level	ft AD I	86.600	GIS2
Q-H relation		Tabulated head vs flow relationship; might also need to use Real Time Control	Field measurement and SVM simulation results
Owner		SPU	GIS
Status	Active or abandoned	Active	GIS

**Notes**

<sup>1</sup> ft AD = feet above NAVD88-North American Vertical Datum of 1988 datum

<sup>2</sup> Use the minimum of ELEV1, ELEV2, ELEV3, ELEV4 or CINVERT – DEPTH unless information shown on As-builts drawings indicates otherwise. Please note that the node invert can also be calculated from the lowest pipe invert connected to the node.